



Port of Portland
April 29, 1997

J-5635
Page 2

Transformer: ser. No. 2978529
Manufacturer: Westinghouse
Style: 958739 D
Voltage: 480 120/240

Circuit Breaker: ser. No. K-6274801-110
Manufacturer: General Electric
Voltage: 15,000
Amperage: 800

Please call if you have any questions regarding this project.

Sincerely,

HART CROWSER, INC.

STACEY W. CALLISON, P.E.
Senior Staff Engineer

RANDI WEXLER
Associate

Attachments: Coleman Metals Letter of Destruction
Coleman Metals Receipt of Transformer and Circuit Breaker with Analytical Data
Oil Re-refining Waste Profile
Oil Re-refining Receiving Record

USEPA SF



1286681